



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

March 8, 2008

Raymond Gregg
City of Geneseo
600 Main
Geneseo, KS 67444

Dear Raymond,

It was good to meet with you. You had been working on you liquid chlorinator pump at the well. We discussed different types of pumps and repairs. It is a good idea to keep a spare unit on hand at all times and plenty of parts to rebuild them at least annually. You have been keeping your chlorine residuals at 1.5 mg/l free chlorine. The range that KDHE requires is between .2 mg/l and 4.0 mg/l free chlorine. You have a bacteriological sampling site plan and you are keeping daily chlorine readings as required. Keeping good records is half the battle of the water operator.

You recently discovered that you have been over pumping well #7 according to your water rights. It may be necessary to apply for more water rights or transfer some from the other wells or simply pump less from well #7 and more from the other two wells. Good daily pumping records should help you stay within your water rights allocations unless you simply need more water.

I hope you will be attending the annual conference this year in Wichita it will be a great place to learn more about the water and wastewater industry. There will be plenty of exhibits and vendors for your shopping needs and other operators to visit with as well as personnel from all the regulatory agencies. So bring your questions and plan on a good time.

Sincerely,

Jon Steele
Circuit Rider

C: Vickie Wessel, KDHE