



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

April 8, 2008

John White
Phillips RWD 1
PO Box 494
Phillipsburg, KS 67661

Dear John;

I enjoyed the recent visits with you and Glen on leak detection, tower controls and interconnect with the City of Speed and repair of the low flow side of the district's master meters and recent OIT status you have entered.

The master meters installed at the PRV vaults are in my opinion the best leak detectors for RWDs of your size. These have been helpful to you in identifying the recent leaks the district has had. You now know the low flow stoppage of the master meters was caused by grass getting lodged in this part of the meter, likely when the contractor was flushing after construction was complete.

As for your daily chlorine residual logs you only need to use the free reagents and not total; total reagents are for chloramines or ammonia and chlorine compounds which you do not use.

Please call Kansas Rural Water Association or my personal work number 785-445-2283 if we can be of further assistance. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs

Sincerely,

Doug Guenther
Technical Assistant

DG:ejr
C: Kay Kinter, Chairman
Norbert Windholz, KDHE, Hays Office
Vicki Wessel, KDHE, Topeka