



PO. Box 226 • Seneca, KS 66538 • 785/336-3760  
FAX 785/336-2751 • <http://www.krwa.net>

May 8, 2009

Vincent Petesch  
Jefferson RWD 11  
8948 NE Brown Rd.  
Meriden, KS 66513

Dear Vincent;

It was a pleasure visiting with you and to provide assistance in the maintenance of the district standpipe. As you know there was a large amount of sediment in the standpipe. I suggest that the district schedule maintenance on the tank at least every three to five years. I also recommend that the meter tap for Jefferson RWD 14 be moved to the north of the valve so that you can provide them water during tank maintenance.

I was glad to hear that you were going to register for the "Chlorination and Disinfection; Compliance with Ground Water Rule" training session that will be held in Lawrence on May 20. Kelly Kelsey with KDHE's Topeka office will present on the Ground Water Rule and Pat McCool with KRWA will be presenting on chlorination and disinfection. This session will provide information to help the city better understand the Ground Water Rule and be ahead of the curve in meeting compliance issues with this Rule.

Thanks again for your time today. Please call Kansas Rural Water Association if we can be of further assistance. Also, visit the KRWA website [www.krwa.net](http://www.krwa.net) for news and information concerning water and wastewater utilities, upcoming training opportunities and other KRWA programs.

Sincerely,

Gary Armentrout  
Circuit Rider

C: Duane Williams, Chairman  
Cathy Wooten, Office Manager