



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760  
FAX 785/336-2751 • <http://www.krwa.net>

May 30, 2009

Carrie Cress  
City of Cedar Point  
PO Box 36  
Cedar Point, KS 66843

Dear Carrie;

It was a pleasure to discuss the operations at the city with you.

**Daily chlorine residuals:** Every public water supply in Kansas is required to monitor chlorine residuals daily and record the results. These records must be kept on file for ten years. We reviewed you daily chlorine residuals and found them to be averaging 1.0 mg/l free chlorine.

**Routine bacteriological monitoring:** Every Kansas public water supply system is required to collect routine bacteriological samples. These samples must be free of coliform bacteria. Your system is required to collect two samples each month to maintain compliance with KDHE. We reviewed your sample results and found them to be acceptable. These sample results must be kept on file for a period of ten years.

**Consumer Confidence Report:** We reviewed your drinking water quality report; everything appears to be in order. You must provide a copy to each customer by July 1. Certify to KDHE that the city has provided notice to customers.

**Ground Water Rule:** We discussed this new rule. I recommend you attend one of the workshops about this subject, as it will also give you some good information about chlorination. The new rule is basically an effort to ensure that ground water sources are free from e-coli and coliform bacteria. If your well has this type of problem you would want to know it and correct it. Again, I urge you to attend one of the upcoming sessions to avoid having to possibly conduct additional testing.

Please call if I can be of any other assistance.

Sincerely,

Jon Steele  
Circuit Rider

C: Mayor and Council Members  
Vickie Wessel, KDHE