



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

May 31, 2009

Denise White
Muddy Water Public Supply
10430 Dora Circle
Wichita, KS 67209

Dear Denise,

It was good to meet with you concerning operations at the restaurant.

Daily chlorine residuals: Every water system in Kansas is required to collect and record daily chlorine residuals. These records must be kept on file for ten years. We flushed the system and tested all the equipment since you are not using the restaurant yet. The equipment seems to be operating fine and we had chlorine residual of .6 mg/l free chlorine at the bar sink. You are scheduled in June then you will need to sample chlorine residuals each time you are open for business.

Routine bacteriological samples: Every public water supply system in Kansas is required to collect routine samples for bacteriological quality your system is required to collect two per month when you are open. We reviewed correct procedures for collecting the samples.

Well grouting: We inspected the well casing and pad. There is a hole and some cracking in the concrete around the casing. We discussed repairing this with a high strength concrete grout mix such as Quikcrete patch mix. This can be purchased in small quantities from a building supply store. A good seal around a well is important in keeping out contamination from getting along the casing and entering the water supply.

Please call if I can be of any other assistance.

Sincerely,

Jon Steele
Circuit Rider

C: Vickie Wessel, KDHE