



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 8, 2009

Steve Hamlin
Baker Hamlin LLC MHP
122 Burgundy Lane
Hays, KS 67601

RE: Operator in Training (OIT) Visit

Dear Steve;

This letter is the follow-up to my on-site visit with you on June 3, 2009, to discuss public water supply system operations.

The daily chlorine residual log shows an average of 1.5 mg/l free for June 3; there have been no bac-t samples which were positive.

I will visit with the Division of Water Resources in Stockton to obtain answers to your questions on the Water Use Report.

Please call the KRWA at 785-336-3760 if we can be of further assistance or my personal number 785-445-2283. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities, and other KRWA programs.

Sincerely,

Doug Guenther
KRWA Technical Assistant

C: Vickie Wessel, KDHE, Topeka
Norbert Windholz, KDHE, Hays