



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760  
FAX 785/336-2751 • <http://www.krwa.net>

June 8, 2009

Jim Petersen  
City of Ransom  
PO Box 494  
Ransom, KS 67661

RE: Operator in Training (OIT) Visit

Dear Jim;

This letter is the follow-up to my on-site visit with you on June 3, 2009, to discuss public water supply system operations.

Your chlorine residual log indicates 0.9 to 1.1 MG/L free. All samples have been negative.

You have registered for your operator exams at Hays for June 17, 2009. I encourage you to review the study guides I provided and the sample quizzes on the KRWA web site for test preparation.

Please call the KRWA at 785-336-3760 if we can be of further assistance or my personal number 785-445-2283. Also, visit the KRWA website [www.krwa.net](http://www.krwa.net) for news and information concerning water and wastewater utilities, training opportunities, and other KRWA programs.

Sincerely,

Doug Guenther  
KRWA Technical Assistant

C: Greg Lutters, Mayor  
Vickie Wessel, KDHE, Topeka