



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 8, 2009

Jason Schneider
City of Schoenchen
PO Box 114
Schoenchen, KS 67667

RE: Operator in Training (OIT) Visit

Dear Jason;

This letter is the follow-up to my on-site visit with you June 3, 2009, to discuss public water supply system operations.

The chlorine residual log indicates an average of 0.8 mg/l. You stated that no samples have been positive since my last visit.

You were not able to attend the training session on the new Ground Water Rule due to work schedule. I will be able to assist you on a plan to be submitted to KDHE by December 1, 2009 on a later visit.

Please call the KRWA at 785-336-3760 if we can be of further assistance or my personal number 785-445-2283. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities, and other KRWA programs.

Sincerely,

Doug Guenther
KRWA Technical Assistant

C: Richard Klaus, Mayor
Vickie Wessel, KDHE, Topeka