



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 8, 2009

Tony Jones
City of Woodston
706 Main
Woodston, KS 67675

RE: Operator in Training (OIT) Visit

Dear Tony;

This letter is the follow-up to my on-site visit with you on June 2, 2009, to discuss public water supply system operations.

Your chlorine residual log indicates a 0.6 on dead end lines to 1.2 mg/l free; there have been no positive samples from the lab. As we discussed I would be glad to assist Tom Kurgis on future projects if the city decides on a nitrate removal plant.

Please call the KRWA at 785-336-3760 if we can be of further assistance or my personal number 785-445-2283. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities, and other KRWA programs.

Sincerely,

Doug Guenther
KRWA Technical Assistant

C: Zane Holsinger, Mayor
Vickie Wessel, KDHE, Topeka
Norbert Windholz, KDHE, Hays
Teresa Schuyler, KDHE, Topeka