



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760  
FAX 785/336-2751 • <http://www.krwa.net>

June 8, 2009

Jonathan Haines  
Countryside Estates  
1010 Reservation Rd.  
Hays, KS 67601

RE: Operator in Training (OIT) Visit

Dear Jonathan;

This letter is the follow-up to my on-site visit with you on June 3, 2009, to discuss public water supply system operations.

The daily chlorine residual log reflects an average of 2.5 to 2.2 mg/l of total chlorine; there have been no positive bac-t samples.

As we discussed, the Hays Fire Department doesn't own the systems fire hydrants and if you feel you need to be present when they flush or test you should contact them on this matter. The matter in which fire hydrants are operated can be a cause of concern. There have been recent leaks and you should make sure there is no additional and unnecessary stress being applied because of the operation of fire hydrants.

Please call the KRWA at 785-336-3760 if we can be of further assistance or my personal number 785-445-2283. Also, visit the KRWA website [www.krwa.net](http://www.krwa.net) for news and information concerning water and wastewater utilities, training opportunities, and other KRWA programs.

Sincerely,

Doug Guenther  
KRWA Technical Assistant

C: Vickie Wessel, KDHE, Topeka  
Norbert Windholz, KDHE, Hays