



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 8, 2009

Jerry Stewart
Jefferson RWD 13
1951 Wellman Rd.
Lawrence, KS 66044

Dear Jerry;

This is a follow up letter to the assistance provided to Jefferson RWD 13 in reference to locating a leak in the district's water main. The results of that assistance are shown below.

A water loss survey was conducted on a 2-inch PVC water line on Republic Road. The leak on the line was located after being isolated between two valves and walking the line. The leak was in heavy brush. The leak was estimated at 25 gpm and it was evident that the break in the line had happened a long time ago.

A second leak was located on a 4-inch PVC line that runs under a creek west of the intersection with 246th Road and Honey Creek Road. Water was coming out of the 6-inch casing on the north side of the creek at approximately 8 to 10 gpm.

We also checked a valve at 246th Road and Dehoff Road. There was no indication of a water leak at this location as was the case also on 21st Street. The water at this location was ground water.

It was good visiting with you and I look forward to seeing you at the Chlorine Safety training session in Kansas City next week.

Please call Kansas Rural Water Association if we can be of further assistance. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, upcoming training opportunities and other KRWA programs.

Sincerely,

Gary Armentrout
Circuit Rider

C: George Pogge, Chairperson
Linda Lipps, Bookkeeper