



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 8, 2009

Curtis Gottschalk
KSU Ag Research Center
1232 North 240 Th Avenue
Hays, KS 67601

RE: Operator in Training (OIT) Visit

Dear Curtis;

This letter is the follow-up to my on-site visit with you on June 3, 2009, to discuss public water supply system operations.

Your chlorine residual log indicates an average of 1.5 to 1.3 MG/L free residual. You stated that there were no positive bacteriological samples. You mentioned being signed up to take your operator exam on June 17, 2009 in Hays. I encourage you to review the materials I supplied on earlier visits.

Please call the KRWA at 785-336-3760 if we can be of further assistance or my personal number 785-445-2283. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities, and other KRWA programs.

Sincerely,

Doug Guenther
KRWA Technical Assistant

C: Vickie Wessel, KDHE, Topeka