



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 12, 2009

Jeff Riley
City of Highland
408 N Nebraska St
Highland, KS 66035

Dear Jeff;

This is a follow up letter to my recent visit to your water system where we discussed your chlorine testing needs.

I am still working on getting your chlorine analyzer and as soon as we receive it I will help you install it. I believe this will help you better control the chlorine residuals and maintain better chlorine residual throughout the distribution system.

On my last visit we discussed the 2-inch meter located near your wells. The new Ground Water Rule will require the city to meet a certain amount of contact time prior to the first tap. If that cannot be achieved, the city could be required to do source water monitoring which means you would have to take a few extra samples a year to make sure you do not have bacteria in the wells. I hope that the city will be able to avoid additional costs.

Please call Kansas Rural Water Association if we can be of further assistance. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs. I will also be in touch.

Sincerely,

Lonnie Boller
Surface Water Tech

C: Bill Butrick, City Clerk