

June 26, 2009

Terry Selensky
Kansas Soldiers Home
710 North 14th
Dodge City, KS 67801

Dear Terry,

It was good to meet with you concerning operation at the Soldiers Home.

Daily chlorine residuals: Each public water supply system in Kansas is required to test chlorine residuals and record the results daily. These records must be maintained on file for public inspection for at least ten years. Your daily chlorine residuals have been averaging 1.0 mg/l free chlorine.

Routine bacteriological sampling: Your system is required to collect two samples each month that are free of bacteria to maintain compliance with the standards of the safe drinking water act. These records must also be kept on file for public inspection for ten years. Your samples have been negative and the system has no monitoring violations at this time.

Gas Chlorination: We discussed gas chlorine operating systems and safety procedures. It is important to observe all the safety recommendations we discussed concerning handling gas chlorine safely. Gas chlorine is very toxic. Always use the buddy system when working around gas chlorine.

Congratulations on your recent certification with KDHE.

Sincerely,

Jon Steele
Circuit Rider

C: Vickie Wessel, KDHE