



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760  
FAX 785/336-2751 • <http://www.krwa.net>

June 26, 2009

Steven Patience  
Operator/Manager  
Linn RWD 2  
PO Box 244  
Mound City, KS 66056

Dear Steve;

The Kansas Rural Water Association typically provides follow-up documentation on many of the tech assistance calls the Association receives. This is a follow-up letter to the ongoing assistance being provided to Linn RWD 2 to identify the causes of the district's water losses.

A small water leak was located and repaired in the pasture area on the east side of Paine Road on a 2-inch PVC line. This leak was flowing at less than .25 gpm; it was difficult to pinpoint. It was the only leak located on this line and as such, could not be the reason for all of the wet ground in the area. It is my opinion that the cause of all of the wet ground in the area is ground water flowing down the hillside.

Plans are being made to test the master sales meters at the Public Wholesale District and at the city of Pleasanton.

Please call Kansas Rural Water Association if we can be of further assistance. Also, visit the KRWA website [www.krwa.net](http://www.krwa.net) for news and information concerning water and wastewater utilities, upcoming training opportunities and other KRWA programs. Thanks for the opportunity for KRWA to be of help to the district.

Sincerely,

Gary Armentrout  
Circuit Rider

C: Charles Leavitt, Chairman  
Andi Bass, Bookkeeper