



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 26, 2009

Nancy Hittle
Western Star RV Ranch
12910 Road 3
Liberal, KS 67901

Dear Nancy;

It was good to meet with you concerning the operator in training program.

Daily chlorine residuals: Every public water supply in Kansas must monitor and record the chlorine residuals daily. These records must be kept on file for public inspection for at least ten years. Your daily chlorine residuals have been averaging .5 mg/l free chlorine. We tested the residual at the washhouse at .5 mg/l free chlorine.

Routine bacteriological monitoring: Every public water supply system in Kansas is required to perform bacteriological sampling and maintain the records of this sampling on file for public inspection for at least ten years. These samples must be free of bacteria contamination to comply with the safe drinking water standards. Your samples have been negative and the park has no monitoring violations at this time.

Routine flushing of the system: Every water supply system should occasionally be flushed. This should be done at points of the distribution system that are dead ends or at the end of lines or where the usage is otherwise low. This can be accomplished by simply fully opening hydrants and allowing them to run for several minutes.

Sincerely,

Jon Steele
Circuit Rider

C: Vickie Wessel, KDHE