

June 29, 2008

Marvin Keller
City of Palco
PO Box 35
Palco, KS 67657

Dear Marvin;

This is the report letter on the recent meter test conducted on Palco's wells. The industry standards for the HP turbine are to be 1.5% plus or minus 100%. The report below indicates 102% or 2 % fast. I believe this meter could be used as is but be tested again in a year for accuracy.

Meter:	2-inch HP Turbine	Neptune	SN 70075472	Palco well meter		
Test Number	Test Flow rate gallons per min.	Meter Volume (entity's meter)	Tester Volume (KRWA's tester)	Entity's meter accuracy (compared to KRWA)	(flow curve adjustment) on test meter	Adjusted Accuracy
1	52	1000	983	101.7%	101.4%	103.2%
2	52	1000	996	100.4%	101.4%	101.8%
3	52	1000	1003	99.7%	101.4%	101.1%

Please call Kansas Rural Water Association or my personal work number 785-445-2283 if we can be of further assistance. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs

Sincerely,

Doug Guenther
Technical Assistant

DG: ejr
C: Robert Kern, Mayor
Norb Winholz, KDHE Hays Office
Tina Rajala, Kansas Water Office