

June 29, 2008

Stan Van Meter
Cloud RWD 1
1386 Jeep Road
Concordia, KS 66901

Dear Stan;

This is in follow-up to the recent leak detection conducted for the water district. As for south of the standpipe we have eliminated this area for any major leakage. The 4-inch main from Noble to 130th and then Plum Streets has a leak that has not surfaced. We were unable to pinpoint the leak. I have spoken with your supplier on Friday and suggested a 4-inch push on style valve be used at 130th Street to cut this line in half to narrow the search area.

Please call Kansas Rural Water Association or my personal work number 785-445-2283 if we can be of further assistance. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs

Sincerely,

Doug Guenther
Technical Assistant

DG: ejr
C: Kurt Kocher, Chairman
Marsha Carpenter, KDHE Salina Office
Tina Rajala, Kansas Water Office