



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 30, 2008

Craig Wright
City of Bird City
PO Box 219
Bird City, KS 67731

Dear Craig;

This is the follow up report on the recent leak detection conducted for Bird City. I understand you repaired the leaks yesterday.

I hope that the correlation and identification and repair of the leak on Third and Rich St. and the service line east of the City Building will improve the city's water loss ratio for the next quarter. I estimated these two leaks at about 15 gallons per minute. The positive water loss calculated in June may be due to the meter reading software or the master meter may have quit or malfunctioned during the month. If you would like the master meter tested for accuracy we can do this at a later date.

Please call Kansas Rural Water Association or my personal work number 785-445-2283 if we can be of further assistance. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs

Sincerely,

Doug Guenther
Technical Assistant

DG: ejr
C: Troy Burr, Mayor
Tina Rajala, Kansas Water Office
Norbert Windholz, KDHE, Hays Office