



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 30, 2008

Bruce Nickel
City of McDonald
PO Box 61
McDonald, KS 67745

Dear Bruce;

This is the follow up report on the recent leak detection conducted for the City of McDonald. The leak detected on Cheyenne Street could not be correlated. This is probably due to a different line material spliced into the services between our set points. The City map indicates this is a 2-inch galvanized main; it is likely corroded from years of use as we have seen in the other sections of town. I believe a new PVC main should be installed to replace this along with new gate valves and risers.

Please call Kansas Rural Water Association or my personal work number 785-445-2283 if we can be of further assistance. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs

Sincerely,

Doug Guenther
Technical Assistant

DG: ejr
C: Norman Davis, Mayor
Norbert Windholz, KDHE Hays Office
Tina Rajala, Kansas Water Office