



PO. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

February 5, 2010

Mary Elliot
City Clerk, city of Haddam
PO Box 95
Haddam, KS 66944

Re: Meter Retest

Dear Mary;

This is a follow up letter to the meter test conducted on Tuesday, February 2, on the Neptune that was not registering correctly on a previous test. We attributed the inaccuracy to the manner in which it was installed. You arranged for the meter to be properly installed. As you can see by the results below, the meter now tested at 98.2% accurate on all three tests. During the tests, it showed no more signs of the register jumping. I had visited with a Neptune meter sales man and asked him if he had ever seen a register do this and he told me that he had seen one mounted vertical do this. Hopefully that was the problem with this one as it tested accurate at the time of my test. I would still recommend you have the meters on the wells tested annually.

2-inch Neptune T10 SN 60483346 Date: 7/06						
Test Number	Test Flow rate gallons per min.	Meter Volume (entity's meter)	Tester Volume (KRWA's tester)	Entity's meter accuracy (flow curve adjustment) (compared to KRWA)	(flow curve adjustment) on test meter	Adjusted Accuracy
1	25	500	514	97.3%	100.9%	98.2%
2	25	1000	1027	97.4%	100.9%	98.2%
3	25	1000	1027	97.4%	100.9%	98.2%

Please feel free to contact Kansas Rural Water Association or me if we can be of further assistance. I enjoyed the opportunity to work with you on this and look forward to working with you in the future. If you have any questions please feel free to call me (785-541-0342). Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs.

Again, thank you for the opportunity.

Sincerely,

Greg Metz
Technical Assistant

C: Jack Adee, Mayor
Joseph Greenwood, Council Member