



PO. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

February 22, 2010

Corey Lyon
City of Aurora
PO Box 99
Aurora, KS 67417

Re: Chlorinator issue

Dear Corey;

This is a follow up to my visit to your city on Friday, February 19 as you requested assistance because of problems with the chlorination equipment.

As we discussed, the check valve was allowing water back into the head. The rubber part can be replaced but the surface of the plastic part needs to also be smoothed to seal. That area needs to also be free of debris. I recommended that you obtain a complete new check valve for a backup and you can also put a second check inline to help prevent water from getting into the head. You will want to make sure you get the correct check valve when ordering; there are low pressure and high pressure check valves.

I also discussed the issue of the cattle lot with our source water tech Doug Helmke. Doug will be glad to look at the area and visit with you about some options you might wish to pursue. I will provide him your number; he will contact you.

When you have some time, please email an updated listing for contacts with the mayor and council as there have been some changes.

I enjoyed the opportunity to work with you on this and look forward to working with you in the future. If you have any questions please feel free to call me at 785-541-0342. Also, visit the KRWA website at www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs.

Again, thank you for the opportunity.

Sincerely,

Greg Metz
Technical Assistant

C: Don Larsen, Mayor