



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 21, 2010

Marty Ramirez
Corps of Engineers, John Redmond Reservoir
1565 Embank Rd SW
New Strawn, KS 66839

Dear Marty;

This is a follow up letter for our recent visit to your system.

We assisted your operators in locating a 220-gallon per minute leak. The leak was located in the Riverside West campgrounds. The water was surfacing along a tree line and following a drainage tube and into a creek.

With the cost of water being purchased from the city of New Strawn, this was an expensive leak.

Please don't hesitate to contact me directly or the Association if we can be of any assistance. My cell phone number is 913-370-0087.

Sincerely,

Tony Kimmi
Technical Assistant

C: Bill Thompkins