



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 22, 2010

Brenda Adkins
Manager, Jackson RWD 3
P.O. Box 350
Holton, KS 66436

Re: Meter test

Dear Brenda;

This is a follow-up report concerning the meter test that you requested. Here are the results of the test:

| Meter: Master Meter 5/8-inch; SN: 5244279; Dated: Aug 2008; Location: #116 | | | | | | |
|---|---------------------------------|-------------------------------|-------------------------------|--|---------------------------------------|-------------------|
| Test Number | Test Flow rate gallons per min. | Meter Volume (entity's meter) | Tester Volume (KRWA's tester) | Entity's meter accuracy (compared to KRWA) | (flow curve adjustment) on test meter | Adjusted Accuracy |
| 1 | 0.25 | 10 | 9.9 | 101.0% | 98.0% | 99.0% |
| 2 | 2 | 50 | 50.2 | 99.6% | 100.4% | 100.0% |
| 3 | 7 | 100 | 100 | 100.0% | 99.5% | 99.5% |

This meter was registering accurately on all three flow rates during the test. I see no reason this meter should not be put back into service.

I enjoyed the opportunity to work with you on this and look forward to working with you in the future. If you have any questions please feel free to call me at 785-541-0342. Also, visit the KRWA Web site at www.krwa.net for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs.

Again, thank you for the opportunity.

Sincerely,

Greg Metz
Technical Assistant