



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

June 30, 2010

Jon Houser
Cherokee RWD 3
2500 Southeast Union Chapel RD
Columbus, KS 66725

RE: Water Loss Survey

Dear Jon;

This letter is a follow up to assistance provided to the district on June 25 and 26, 2010. The assistance was to locate leaks in the district's water lines that were preventing the district's tower from filling.

Three leaks were located and repaired on Friday with an approximate recovery total of 55,000 gpd. No additional leaks were located on Saturday. The level of water in the storage tank was beginning to improve on Saturday.

Thank you for the opportunity to assist the district. I look forward to working with you in the future should you need any further assistance. A training schedule is available on the KRWA website at www.krwa.net. If any problems arise or if you are in need of assistance in any way, please contact us.

Sincerely,

Gary Armentrout
ARRA Circuit Rider

C: Ted Houser, Chairman