



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

July 14, 2010

Jason Schneider
City of Schoenchen
PO Box 114
Schoenchen, KS 67667

RE: Operator in Training (OIT) Visit

Dear Jason;

This letter is the follow-up to my discussions with you in June and July.

The extra E-coli bottles you received were due to an inaccuracy in records of Schoenchen's number of operating wells.

Your CL2 residual logs reflect a 0.6 to 0.9 mg/l free average during both visits; one had a positive bacteriological sample; you had not received the result letter at that time. As you now know, just use the two bottles for two points of entries used and return the other three. You will have to collect three extra system samples also before the end of July. As you mentioned your lack of time because of extra duties at work, a small system operator only needs to take 5 hours for training every two years to maintain the license.

Please call the KRWA 785-336-3760 if we can be of further assistance or my personal number 785-445-2283. Also, visit the KRWA website www.krwa.net for news and information concerning water and wastewater utilities, training opportunities, and other KRWA programs. Let me know if I can be of other help.

Sincerely,

Doug Guenther
KRWA Technical Assistant

C: Richard Klaus, Mayor
Vickie Wessel, KDHE, Topeka
Norbert Windholz, KDHE, Hays
Teresa Schuyler, KDHE, Topeka