



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760  
FAX 785/336-2751 • <http://www.krwa.net>

July 15, 2010

Rodney Huffman  
City of Oakley  
209 Hudson Ave.  
Oakley, KS 67748

Dear Rodney;

This is the meter test report for the Kansas Country Inn Motel meter. This meter tested 101% accurate you can see the results below.

<b>3-inch Neptune HP</b>		<b>SN: 23843082</b>		<b>Kansas Country Inn</b>		
Test Number	Test Flow rate gallons per min.	Meter Volume (entity's meter)	Tester Volume (KRWA's tester)	Entity's meter accuracy (compared to KRWA)	(flow curve adjustment) on test meter	Adjusted Accuracy
1	210	1000	1067	93.7%	100.7%	94.4%
2	28	100	97	103.1%	101.8%	104.9%
3	28	100	98	102.0%	101.8%	103.9%

The industry standard for this meter is to test 1.5% plus or minus 100%. In my opinion, this meter was still operating properly despite its age but I also believe the Mag Meter used now a better choice for the motel.

Please call Kansas Rural Water Association or my personal work number 785-445-2283 if we can be of further assistance. Also, visit the KRWA website [www.krwa.net](http://www.krwa.net) for news and information concerning water and wastewater utilities, training opportunities and other KRWA programs

Sincerely,

Doug Guenther  
Technical Assistant

DG: ejr  
C: Jerry Robben, Mayor  
Brandon Buchanan, City Administrator  
Norbert Windholz, KDHE, Hays