



P.O. Box 226 • Seneca, KS 66538 • 785/336-3760
FAX 785/336-2751 • <http://www.krwa.net>

July 30, 2010

Dave Jermark
City of Green
401 5th ST.
Green, Ks 67447

Dear Dave;

It was good to visit with you concerning the new operator program. Here are comments concerning our phone visit on the 19th.

Daily chlorine residuals: Just as a reminder and a possible test question all public water supply systems in Kansas must provide continuous chlorination in the distribution system and record the residual readings daily. These records must be kept on file and available for public inspection for ten years. Your system is using free chlorine. The minimum chlorine residual is .2 mg/l free and the maximum is 4.0 mg/l free chlorine. Your daily chlorine residuals have been averaging .5 mg/l free chlorine.

Routine Bacteriological monitoring: You reported that all samples have been taken recorded and that none have been positive for Bac-T. You also reported that you were maintaining around a 1.2 mg/l free chlorine and recording them daily.

Training Sessions/workshops: We discussed you wanting to attend the training in Lawrence but due to your job and scheduling you would be unable to. You did state that you are planning to try and test in Topeka in September. I wish you good luck.

Please let me know if we can be of any help. Will look forward to seeing you again soon.

Sincerely,

Greg Metz
Technical Assistant

C: Vickie Wessel, KDHE